

UTILITY ANALYSIS

ELECTRICAL SERVICE

MEMO

To: Vladimir Lyubetsky/ DRA Architects

From: Mark J. Blundell

Date: 06/04/2021

RE: Northeast Metropolitan Regional Technical High School
Electric Service Availability Coordination Approach

Project #: 60-20-409

Existing school building is served via existing overhead 13.8 kV line routed down Hemlock Road from the intersection of Farm Street.

Existing primary electric service terminates at the building via a riser pole with fused cutouts. Primary electric service conduits are routed down riser pole to an underground electric service and terminate in a utility co. transformer vault.

Transformer vault contains 3 transformers rated at 1000kVA 13.8kV to 277V single phase units located inside the school. Transformers are connected via collector bus duct with cable tap boxes and power is extended to main switchboard. Secondary electric service is 480/277volts, 3 phase 4 wire.

Existing main switchboard is rated at 480/277volts, 3 phase 4 wire with a capacity of 4000A.

Based on WMGL records, existing maximum demand is 600-700kVA range, indicating sufficient capacity exists to serve existing building and new building construction loads. Upon demolition of existing school, electric service capacity from existing school building will be reallocated to new school building.

Please refer to the attached electric load letter created to get the coordination process started with the electric company. Please refer as well to attached electric company response letter which verifies that electric service will be available for the project.

cc: KJC; SPS; KJA - Bala

Mark J. Blundell

From: Mark J. Blundell
Sent: Wednesday, March 17, 2021 10:40 AM
To: Vincent McMahon
Cc: Kevin J. Alles
Subject: RE: standards
Attachments: 2021-02-25 NEMT Landscape Slides - New Connections to Existing Electric Services.pdf; 60-20-409 Projected Preliminary Electrical Connected Loads.pdf

Categories: Filed by Newforma

Vinnie

Nice to speak with you today and thank you for the construction standards information...the transformers with integral switches sound like they will eliminate any primary switch requirements...

As we discussed, we anticipate serving the building with 2 transformers each serving a 3000A switchboard at 480/277V 3phase with Kirk key interlock.

Attached is our anticipated connected loads letter with a proposed preliminary primary service routing for your review and comment based on a Google Earth assessment. More information will be provided once the civil plans are developed.

We will discuss the electrical vehicle charger and photovoltaic arrangements and potential for running the generator in a peak shaving mode with the Architect.

Thank you

Mark J. Blundell, LEED AP

Electrical Engineer | Direct 857-444-8603 | mjb@bala.com

BALA CONSULTING ENGINEERS

52 Temple Place | Boston, MA 02111 | 617 357 6060 ext. 603 | www.bala.com

*** **For our latest insights on COVID-19 impacts to facilities [Click Here.](#)** ***



This email and any files transmitted with it are the property of Bala Consulting Engineers, are confidential, and are intended solely for the use of the individual, group, or entity to whom this email is addressed. Any other use, retention, dissemination, forwarding, printing, or copying of this email is strictly prohibited.

From: Vincent McMahon <vmcmahon@wmgld.com>
Sent: Wednesday, March 17, 2021 9:32 AM
To: Mark J. Blundell <MJB@bala.com>
Subject: standards

Vinnie McMahon

Senior System Engineer

Wakefield Municipal Gas & Light Department

480 North Avenue, Wakefield MA 01880

Phone: 978-491-7746

vmcmahon@wmgld.com





WMGLD
P.O. BOX 190 480 North Ave.
Wakefield, MA 01880
Tel. (781) 246-6363 Fax (781) 246-0419

Peter D. Dion, General Manager

John J. Warchol, Chair
Philip Courcy, Secretary
Kenneth J. Chase, Jr.
Jennifer Kallay
Thomas Boettcher

December 2, 2020

Dear Kevin Alles,

The Wakefield Municipal Gas & Light Dept currently provides power to Northeast Metro Tech at 100 Hemlock Rd, Wakefield MA. We understand a new school is being planned and will be built next to the existing school. WMGLD is committed to providing power to the new Northeast Metro Tech and maintaining power to the existing school until it is no longer needed.

Regards,

Vinnie McMahon
Senior Engineer, WMGLD
vmcmahon@wmgld.com



Projected Preliminary Electrical Connected Loads

Lighting (Code 3 watts/SF: 1,350 kW) (projected installed load at .75w/SF roughly 450kW, plus site lighting, 500 kW)	357 kW
Receptacles (1 watt / SF)	450 kW
Mechanical:	
• Miscellaneous Electric Heat (Cabinet Htrs/Unit Heaters/Etc.)	50 kW
• Heat Recovery Units Avg 20hp each - 180hp	135 kW
• Air Cooled Heat Pumps 200 tons	250 kW
• Roof Top Units Avg 150A each	375 kW
• Make-up Air Unit	25 kW
• Miscellaneous AC Split Systems 25 at 2 tons each	62 kW
• Exhaust Fans Majority fractional hp 1/3 – 1/4 Largest 3hp	15 kW
• Pumps (Est. qty 6 at 15 hp each/90 hp) 3 Hot Wtr Circ/3 Chilled Wtr Circ	67 kW
Plumbing:	
• Electric Hot Water Heaters	15 kW
• Miscellaneous Circ Pumps (Fractional hp)	5 kW
• Miscellaneous Pumps	5 kW
Elevators (two at 60 hp)	90 kW
Miscellaneous Power (Appliances, Copiers, Elec Heat Trace, Art Rm equipment, Field House Equipment, etc.)	100 kW
Kitchen (all electric)	200 kW
Miscellaneous Equipment	45 kW
Total:	2,201 kW
Call it	2,250 kW



Projected Preliminary Electrical Connected Loads with code applied Demand Factor:

2,250 kW/450,000 SF =	5kW/SF
First 3w/SF at 100%	3W/SF
Plus	
Over 33 through 220 w/SF at 75%	1W/SF
Calculated demand load 4w/SF =	1,800 kW

Preliminary Design is based on two new Utility Company mounted transformers to serve the building at 277/480V, 3 phase, 4 wire.

Based on projected connected loads, proposed secondary service is 6,000 amps.

Project will have an exterior self-contained diesel generator.