





OPM SUBMITTAL REVIEW & COORDINATION  
**COMMISSIONING CONSULTANTS REVIEW**


6B.2.1 - 03


 <b>Consulting Engineering Services 2022604.00 G</b>		<b>CxA DESIGN REVIEW COMMENTS - Mechanical and Controls (ATC) Specifics</b>							
		<b>Northeast Metropolitan Regional Vocational High School</b>							
Project Name:		Northeast Metropolitan Regional Vocational High School			Reviewing Agency:		Consulting Engineering Services		
Project No.:		2022604.00 G			Reviewed By:		Jeanine Palmieri		
Milestone:		60% CD			Review Date:		12/4/2022		
NO.	Drawing/ Spec Section	Detail/ Room Number	DISCIPLINE	Cx Review Comments	REVIEW COMMENT BY:	Designer Response	Follow Up Comments	Reviewer Response (Open/Closed)	Review Set
CES 1.01	230993.11 and M Drawings	Split System A/C Units (Typical)	M	230993.11, 1.15, C for split A/C units it indicates Spaces served by these systems shall be instrumented with temperature sensors for monitoring by the BMS, alarming temperatures out of range. Monitoring sensors now shown on drawings.	CES	Will be indicated in a future submission.		Open	60%CD
CES 1.02	230993.11 and M Drawings	EUH/ECUH (Typical)	M	230993.11, 1.13, B for electric cabinet unit heaters indicates that the shall be provided with manufacturers thermostats for field installation but also shall be instrumented with temperature sensors for monitoring by the BMS and alarming when 5°F below the temp setpoint (adj.) Monitoring sensors not yet shown on	CES	This will be clarified in a future submission.		Open	60%CD
CES 1.03	M Drawings	General Comment - Control Sensors	M	Control sensor placement on drawings not yet complete	CES	This will be indicated in a future submission.		In Progress	60%CD
CES 1.04	M1-1-1A	TIT A107	M	No exhaust Shown to this toilet room	qqw	Exhaust to this toilet room will be indicted in a future submission.		Open	60%CD
CES 1.05	M1-1-1A and M5-0-1	F-18 (Kitchen Area)	M	Review schedule to ensure location and "serving" for F-18 are accurate. Appears to be located in the kitchen A108 and serve Recycling Room A109, custodial A113, Office A104, Tlt A106 and should serve A107 (no grille shown in there currently)	CES	Will review and revised.		Open	60%CD
CES 1.06	M1-1-1A	Elevator Machine Room	M	What is this room (Elev Machine Room?) and how is it accessed? No door shown. Split A/C in space missing Tag - Assumed 2-4 based on M1-3-1A	CES	The location of this AC will be revised in a future submission.		Open	60%CD
CES 1.07	M1.1-0D	General Comment	M	Ductwork Sizing in progress. To be reviewed for completeness during next review.	CES	Noted.		In Progress	60%CD
CES 1.08	M1.1-0D	Auto Technology D003	M	CO/NO2 System - Is this being monitored by the BMS or is this 100% Standalone? If monitored, this should be written into the spec.	CES	It will be monitored by the BMS and will be included in the specification in a future submission		Open	60%CD
CES 1.09	M1.1-0D	VAV Schedules (Typical)	M	Sound Data appears to be incomplete	CES	Will be completed in a future submission.		Open	60%CD
CES 1.10	M1.1-0D	Receiving A110	M	Confirm sufficient heat near this exterior door.	CES	Confirmed. EUH to be provided in Receiving A110.		Open	60%CD
CES 1.11	M1.1-0D	Carpentry A141	M	Confirm necessary controls will be provided with relocated dust collector.	CES	Confirmed.		Open	60%CD
CES 1.12	M1-1-2A	CR A224, 225, 226, 227	M	Suggest moving room name indication for clarity.	CES	Noted.		Open	60%CD
CES 1.13	M1-1-2B	Records B227	M	Does this records area require any ventilation?	CES	Ventilation will be added in a future submission.		Open	60%CD
CES 1.14	M1-1-2B	CR B212 Typical	M	Sensors in progress. To be reviewed on next set. Suggest drawing whips to each piece of equipment controlled for clarity.	CES	Controls and sensors will be clarified in a future submission.		Open	60%CD
CES 1.15	M1-1-2B	TLT 217?	M	Exhaust not shown in space	CES	Exhaust will be indicated in future submission.		Open	60%CD
CES 1.16	M1-1-3A	Elev Machine EE	M	Is split A/C needed in here?	CES	AC noted in item number CES 1.06 is to be relocated to this elevator machine room in a future submission.		Open	60%CD
CES 1.17	M1-1-3A	Digital Learning A308 (typical)	M	Similar locations on other pages show T and TC2 serving similar areas. Is this shown correctly here? If the Thermostat controls the VRF. What is controlling the electric reheat on the VAV?	CES	This is shown correctly. The thermostat is controlling the VRF FCU and the CO2 sensor is controlling the VAV. The HRU discharge air temperature will be reset based on outdoor air temperature. VAVs connected to HRU-1, 2, 3 will not be		Open	60%CD


<div><div>Consulting Engineering Services 2022604.00 G</div></div>		CxA DESIGN REVIEW COMMENTS - Mechanical and Controls (ATC) Specifics							
		Northeast Metropolitan Regional Vocational High School							
Project Name:		Northeast Metropolitan Regional Vocational High School			Reviewing Agency:		Consulting Engineering Services		
Project No.:		2022604.00 G			Reviewed By:		Jeanine Palmieri		
Milestone:		60% CD			Review Date:		12/4/2022		
NO.	Drawing/ Spec Section	Detail/ Room Number	DISCIPLINE	Cx Review Comments	REVIEW COMMENT BY:	Designer Response	Follow Up Comments	Reviewer Response (Open/Closed)	Review Set
CES 1.18	HVAC Drawing Notes	General Comment	M	Update detail and drawing number for reference.	CES	Noted.		Open	60%CD
CES 1.19	M1-1-LB	Detail 2	M	Room names not identified on plan.	CES	Will update in a future submission.		Open	60%CD
CES 1.20	M1-3-0C	Near Coach OFF C024	M	What is this space. Is there a FCU that serves Coaches office C024 also? FCUS should be tagged.	CES	Will be revised in a future submission.		Open	60%CD
CES 1.21	M1-3-1D	Elec Rm	M	Split A/C not tagged	CES	Will be tagged in a future submission.		Open	60%CD
CES 1.22	M5-0-3	Sound Attenuator Schedule	M	Schedule not yet filled in.	CES	Will be completed in a future submission.		Open	60%CD
CES 1.23	230993.11	Air Handling/Rooftop Units	M	Suggest identifying sequences with associated unit numbers for clarity.	CES	Sequences of operation will be revised and clarified in a future submission.		Open	60%CD
CES 1.24	230993 and M Dwgs	Control Diagrams	M	Will control diagrams be provided?	CES	No.		Open	60%CD


 <b>Consulting Engineering Services 2022604.00 G</b>		CxA DESIGN REVIEW COMMENTS - Electrical							
		Northeast Metropolitan Regional Vocational High School							
Project Name:		Northeast Metropolitan Regional Vocational High School			Reviewing Agency:		Consulting Engineering Services		
Project No.:		2022604.00 G			Reviewed By:		Scott Sullivan		
Milestone:		60% CD			Review Date:		12/5/2022		
NO.	Drawing/ Spec Section	Detail/ Room Number	DISCIPLINE	Cx Review Comments	REVIEW COMMENT BY:	Designer Response	Follow Up Comments	Reviewer Response (Open/Closed)	Review Set
CES 2.01	E1-1-0	MSB-1A - Main Elec C001	E	PLEASE REVIEW INSTALLTION METHODS/FUTURE REPLACEMENT OF LARGER EQUIPMENT SUCH AS THE MAIN SWITCHBOARD, TRANSFORMERS, ETC. DOUBLE DOORS INTO ELECTRICAL ROOM WILL ACCOMMODATE, HOWEVER, THIS LEADS INTO A CORRIDOR WITH STANDARD WITH DOORS AT STAIRS.	CES	Accommodation for replacement of larger equipment will be reviewed.		Open	60% CD
CES 2.02	E1-1-0	PV Panelbaord - Main Elec C001	E	PLEASE INDICATE LOCATION OF PV DISCONNECT SWITCH. NORMALLY REQUIRED AT EXTERIOR ADJACENT TO UTILITY METER/UTILITY TRANSFORMER.	CES	Location of PV switch will be included in future submission.		Open	60% CD
CES 2.03	E1-1-0	Elev Mach C012	E	DISCONNECTS ARE REQUIRED AT DOOR STRIKE SIDE OF DOOR.	CES	Disconnect location will be revised.		Open	60% CD
CES 2.04	E1-1-0C	Key Plan (Typical)	E	PLEASE EDIT KEYPLAN TO MATCH	CES	Key plans will be revised to match.		Open	60% CD
CES 2.05	E1-1-0D	General Comment	E	PLEASE REVIEW ARTICLE 511 REQUIREMENTS FOR WIRING AND DEVICES AS DESIGN PROGRESSES.	CES	Any area classifications and requirements for wiring devices will be coordinated as design progresses.		Open	60% CD
CES 2.06	E1-1-MC/MD and On	General Comment	E	DRAWING INCOMPLETE, CANNOT BE REVIEWED. Not ready for a 60% CD review.	CES	The scope indicated on the drawings is sufficient for a 60%CD pricing set. Drawings issued for the 60%CD MSBA submission will meeting MSBA 60%CD requirements with the exception of all circuiting being completed.		Open	60% CD

 <b>Consulting Engineering Services 2022604.00 G</b>		<b>CxA DESIGN REVIEW COMMENTS - Fire Protection</b>							
		<b>Northeast Metropolitan Regional Vocational High School</b>							
Project Name:		Northeast Metropolitan Regional Vocational High School				Reviewing Agency:		Consulting Engineering Services	
Project No.:		2022604.00 G				Reviewed By:		Del Smith	
Milestone:		60% CD				Review Date:		12/5/2022	
NO.	Drawing/ Spec Section	Detail/ Room Number	DISCIPLINE	Cx Review Comments	REVIEW COMMENT BY:	Designer Response	Follow Up Comments	Reviewer Response (Open/Closed)	Review Set
CES 3.01	FP1-1-0.5CD	Detail 2	FP	Sprinklers are shown too close together	CES	Sprinkler graphics/layout to be revised accordingly.		Open	60% CD
CES 3.02	FP1-1-0.5CD	Detail 3	FP	It appears some of this work is also shown on the full plans.	CES	Sprinkler graphics/layout to be revised accordingly.		Open	60% CD
CES 3.03	FP1-1-0C (Typical)	Key Plan	FP	Correct hatching on key plan to indicate area shown. typical for all sheets	CES	Noted, will address for future submission.		Open	60% CD
CES 3.04	FP1-1-0C	Hatched Area above Corridor C010	FP	Light Hazard Area label shown in Ordinary Hazard Area	CES	Light Hazard Area, is noted for toilet room. Will be addressed for clarity on partial plans.		Open	60% CD
CES 3.05	FP1-1-0C	Generator Panels C007 and Elec Main Elec C001	FP	Should these areas be shown as Ordinary Hazard?	CES	Areas will be noted as Ordinary Hazard.		Open	60% CD
CES 3.06	FP1-1-0C	Plumbing Room C008	FP	Where does the drain piping for the floor control valves terminate?	CES	Drain piping termination point shall be indicated in future submission.		Open	60% CD
CES 3.07	FP1-1-0C	Elev #2 E2	FP	Is coverage required for the elevator pit and for Elevator Machine Room	CES	These areas do not require sprinkler coverage.		Open	60% CD
CES 3.08	FP1-1-0C	Paint Booth	FP	Sprinkler heads shown on the wall. Should these be relocated?	CES	Sprinklers are above paint booth at the shop ceiling.		Open	60% CD
CES 3.09	FP1-1-0C	Paint Booth	FP	The two sets of sprinklers appear to be too close together. is there a separation not readily visible on the plans? Typical for both spray booths	CES	One set of sprinkler heads are shown within the booth. Other set is intended to provide coverage at the shop ceiling outside the paint booth. Plans shall be updated for clarity.		Open	60% CD
CES 3.10	FP1-1-0C	Off C022E	FP	Sprinkler heads shown too close together and conflicting hazard classifications shown in the is area.	CES	Hazard classifications are for rooms under mezzanine. Classifications to be modified as needed for clarity. Sprinkler layout to be modified.		Open	60% CD
CES 3.11	FP1-1-0C	TLT C022C	FP	Heads shown too close together.	CES	Sprinkler below mezzanine and at shop ceiling appearing on same plan. Graphics to be modified.		Open	60% CD
CES 3.12	FP1-1-0C	Auto Collision C022	FP	Heads shown too close together.	CES	Sprinkler layout to be modified accordingly.		Open	60% CD
CES 3.13	FP1-1-0C	Stair 7	FP	Is this a drain riser? Where does it terminate? Also the symbol is not in the legend. Is this a fire department hose valve?	CES	Symbol is a fire department hose valve. Drain riser to terminate through exterior wall underside of stair.		Open	60% CD
CES 3.14	FP1-1-0C	Auto Collision C022	FP	Missing sprinkler head on the far right side of the plan.	CES	Sprinkler layout to be modified accordingly.		Open	60% CD
CES 3.15	FP1-1-0C	Stair 6	FP	There appears to be something missing in this location. Also, the various pipes/risers are not labeled	CES	6" fire standpipe riser, 3" sprinkler drain riser to be labeled.		Open	60% CD
CES 3.16	FP1-1-0C/D	Stair 6	FP	Sprinkler coverage in the stair looks deficient. Typical	CES	Sprinklers will be shown at underside of bottom landing and at top of the stairways. Typical for all stairways.		Open	60% CD
CES 3.17	FP1-1-0D	Related C022D and TLT C022C	FP	Sprinklers shown too close together	CES	Sprinkler below mezzanine and at shop ceiling appearing on same plan. Graphics to be modified.		Open	60% CD
CES 3.18	FP1-1-0D	Stair 6	FP	Where does the drain piping terminate?	CES	Drain riser to terminate through exterior wall underside of stair.		Open	60% CD
CES 3.19	FP1-1-0D	Just above Stair 6	FP	What does the riser serve?	CES	Riser serves auditorium fire department valve connection.		Open	60% CD

 <b>Consulting Engineering Services 2022604.00 G</b>		<b>CxA DESIGN REVIEW COMMENTS - Fire Protection</b>							
		<b>Northeast Metropolitan Regional Vocational High School</b>							
Project Name:		Northeast Metropolitan Regional Vocational High School				Reviewing Agency:		Consulting Engineering Services	
Project No.:		2022604.00 G				Reviewed By:		Del Smith	
Milestone:		60% CD				Review Date:		12/5/2022	
NO.	Drawing/ Spec Section	Detail/ Room Number	DISCIPLINE	Cx Review Comments	REVIEW COMMENT BY:	Designer Response	Follow Up Comments	Reviewer Response (Open/Closed)	Review Set
CES 3.20	FP1-1-0D	Area outlined in detail 3 callout	FP	Conflicting hazard classification	CES	Hazard classifications are for rooms under mezzanine. Classifications to be modified as needed for clarity. Sprinkler layout to be modified.		Open	60% CD
CES 3.21	FP1-1-0D	Area outlined in detail 3 callout	FP	Sprinkler heads shown too close together. Are they at different elevations?	CES	Sprinkler below mezzanine and at shop ceiling appearing on same plan. Graphics to be modified.		Open	60% CD
CES 3.22	FP1-1-1A	Stair 1 S1	FP	Will sprinkler coverage be provided in this area?	CES	Sprinkler coverage will be provided in this area as required.		Open	60% CD
CES 3.23	FP1-1-1A	Kitchen A108	FP	Has full coverage been provided?	CES	Full sprinkler coverage to be provided except for areas under hoods, covered under separate ANSUL system.		Open	60% CD
CES 3.24	FP1-1-1A	Stair 2 S2	FP	Is a fire department hose valve provided here?	CES	Fire department hose valve to be noted at Stair 2.		Open	60% CD
CES 3.25	FP1-1-1A	Area below Tool Crib B101H	FP	This space appears to have no doors. Is sprinkler coverage required?	CES	Sprinkler coverage is required, this area is accessible from a ladder to the mezzanine level.		Open	60% CD
CES 3.26	FP1-1-1B	Fire Pump Room B105	FP	Where is fire pump test header shown?	CES	Fire pump test header shown on north exterior wall outside fire pump room.		Open	60% CD
CES 3.27	FP1-1-1B	Fire Pump Room B105	FP	10" service shown on riser diagram	CES	Riser diagram shall be updated to show 8" service.		Open	60% CD
CES 3.28	FP1-1-1B	Fire Pump Room B105	FP	Pump shown backwards	CES	Pump layout to be revised.		Open	60% CD
CES 3.29	FP1-1-1B	Fire Pump Room B105	FP	Piping doesn't match riser	CES	Piping to be coordinated accordingly.		Open	60% CD
CES 3.30	FP1-1-1B/C	General Comment	FP	piping not visible in multiple areas	CES	Drawings to be revised for clarity.		Open	60% CD
CES 3.31	FP1-1-1B	Plumbing and Pipe Fitting B101	FP	FHVC tag shown. What is this associated with?	CES	Fire hose valve connection for standpipe system.		Open	60% CD
CES 3.32	FP1-1-1B	Tool Crib	FP	Confirm sprinkler heads are shown properly.	CES	Heads above and below mezzanine level appearing. Graphics to be modified accordingly.		Open	60% CD
CES 3.33	FP1-1-1B	General Comment	FP	Should LH tags be on the part plan on P1-1-1.5AB?	CES	Correct. Tag locations to be modified.		Open	60% CD
CES 3.34	FP1-1-1C	Stair 4 S4	FP	Where does the drain terminate	CES	Drain terminates through exterior wall at Lower Level.		Open	60% CD
CES 3.35	FP1-1-1C	Cust A205	FP	Identify symbols shown in space.	CES	Graphical error. Should not appear on FP drawings.		Open	60% CD
CES 3.36	FP1-1-2C	Near Corridor C201	FP	6" FSP and 3" SDR not pointing to anything outside Corridor	CES	To be deleted.		Open	60% CD
CES 3.37	FP1-1-2C	Corridor C206	FP	Clarify why two types of sprinklers are provided in such close proximity to each other	CES	Sprinkler layout to be modified accordingly.		Open	60% CD
CES 3.38	FP1-1-2C	Proscenium opening	FP	Are any special fire protection measures necessary at the proscenium opening?	CES	Sprinklers required at underside of walkway. Window sprinklers are required at glass separation at upper levels.		Open	60% CD
CES 3.39	FP1-1-3A	STOR A314	FP	Sprinkler coverage in this area does not seem to match the background	CES	Sprinkler layout to be modified accordingly.		Open	60% CD

 <div> Consulting Engineering  Services 2022604.00 G </div>		CxA DESIGN REVIEW COMMENTS - Fire Protection							
		Northeast Metropolitan Regional Vocational High School							
Project Name:		Northeast Metropolitan Regional Vocational High School				Reviewing Agency:		Consulting Engineering Services	
Project No.:		2022604.00 G				Reviewed By:		Del Smith	
Milestone:		60% CD				Review Date:		12/5/2022	
NO.	Drawing/ Spec Section	Detail/ Room Number	DISCIPLINE	Cx Review Comments	REVIEW COMMENT BY:	Designer Response	Follow Up Comments	Reviewer Response (Open/Closed)	Review Set
CES 3.40	FP1-1-4D	General Comment	FP	The entire 4th floor appears to be fed off of a single riser. Verify the floor area doesn't exceed that allowed by NFPA 13. Check for other floors as well	CES	Noted and will be reviewed.		Open	60% CD
CES 3.41	FP1-2-1A	General Comment	FP	Is more than one standpipe connection required for the roof?	CES	Roof area standpipe coverage shall be reviewed and confirmed.		Open	60% CD
CES 3.42	FP5-0-1	Detail 1	FP	It seems redundant to have check valves on the inlet and outlet of the fire pump	CES	FP riser diagram to be revised to reflect piping layout.		Open	60% CD
CES 3.43	FP5-0-1	Detail 1	FP	Four ZCV-A shown on the floor plan but three shown on this detail.	CES	FP riser diagram to be revised to reflect piping layout.		Open	60% CD
CES 3.44	FP6-0-1	Detail 7	FP	Fire Pump Tag incomplete	CES	Noted. Will address.		Open	60% CD
CES 3.45	FP6-0-1	Detail 8	FP	Where is the combination standpipe with PRV required. PRV not found on plans.	CES	PRV requirements to be reviewed and addressed accordingly.		Open	60% CD

		CxA DESIGN REVIEW COMMENTS - Plumbing							
		Northeast Metropolitan Regional Vocational High School							
Project Name:		Northeast Metropolitan Regional Vocational High School			Reviewing Agency:		Consulting Engineering Services		
Project No.:		2022604.00 G			Reviewed By:		Del Smith		
Milestone:		60% CD			Review Date:		12/5/2022		
NO.	Drawing/ Spec Section	Detail/ Room Number	DISCIPLINE	Cx Review Comments	REVIEW COMMENT BY:	Designer Response	Follow Up Comments	Reviewer Response (Open/Closed)	Review Set
CES 4.01	P0-0-1 (applicable to all sheets)	General Comment	P	Show locations of cleanouts	CES	Cleanout locations will be added in future submission		Open	60% CD
CES 4.02	P0-0-1 (applicable to all sheets)	General Comment	P	Many pipes are shown rising in locations where they will not be concealed. Confirm intent.	CES	Piping to be coordinated with architect accordingly.		Open	60% CD
CES 4.03	P0-0-1 (applicable to all sheets)	General Comment	P	Floor drains in many areas do not appear to be vented. Clarify intent.	CES	Floor drain venting to be added in future submission.		Open	60% CD
CES 4.04	P1-0-0A	Kitchen A108	P	Sanitary connection to floor grate?	CES	Drain connection to be added in future submission		Open	60% CD
CES 4.05	P1-0-0A	Recycling A109	P	Location shown to grease waste. Should it go to sanitary instead?	CES	FD waste shall go to sanitary.		Open	60% CD
CES 4.06	P1-0-0A	Servery A112	P	Several of the storm pipe risers do no appear to be in enclosures. Verify exposed piping is acceptable	CES	Final location to be confirmed with architect.		Open	60% CD
CES 4.07	P1-0-0A	Carpentry A141	P	Is the intent to have floor drains in carpentry?	CES	Yes.		Open	60% CD
CES 4.08	P1-0-0A	Carpentry A141	P	Why do the other floor drain in this area go through an oil separator but this one does not? Confirm intent. Refer to location on redline markup.	CES	Emergency shower/eyewash discharge to sanitary system.		Open	60% CD
CES 4.09	P1-0-0B	Cosmetology B120	P	How are these fixtures vented?	CES	Venting to be added below slab in future submission.		Open	60% CD
CES 4.10	P1-0-0C	Elev #2 E2	P	Where does the pump discharge to?	CES	Pump will discharge and drain to sanitary system.		Open	60% CD
CES 4.11	P1-0-0C	Shower	P	Sanitary connection to fixtures missing. Also relocate room name/ number to proper location.	CES	Noted. Will be revised in future submission.		Open	60% CD
CES 4.12	P1-0-0C	TLT C022C	P	Floor drain not connected to sanitary	CES	Noted. Connection to be added in future submission		Open	60% CD
CES 4.13	P1-0-0C	Auto Collision C022	P	10" Storm - Appears to be an excessively convoluted route. Clarify intent	CES	Routing to be simplified.		Open	60% CD
CES 4.14	P1-0-0C	Metal Fabrication C004	P	8" Storm - Riser appears to go through a piece of equipment. Clarify intent	CES	Riser shall drop against column. Location will be revised in future submission.		Open	60% CD
CES 4.15	P1-0-0C	Metal Fabrication C004	P	Floor cleanout is located under a piece of equipment and may not be readily accessible. Clarify intent/review location	CES	Location shall be revised in future submission.		Open	60% CD
CES 4.16	P1-1-1A	Dry Storage A103	P	Piping to fixture not shown	CES	Piping to be indicated in future submission.		Open	60% CD
CES 4.17	P1-1-1A	Cooler A102	P	Exposed Piping? Confirm intent.	CES	Final location to be coordinated with architect.		Open	60% CD
CES 4.18	P1-1-1A	OFF A104	P	8" vent for radon mitigation - exposed piping rising in the middle of the room? Verify intent.	CES	Final location to be coordinated with architect.		Open	60% CD
CES 4.19	P1-1-1A	Receiving A110	P	Piping shown in space but where is it going?	CES	Piping layout to be completed and intent clarified in future submission.		Open	60% CD

<div></div> <div>Consulting Engineering Services 2022604.00 G</div>		CxA DESIGN REVIEW COMMENTS - Architectural								
		Northeast Metropolitan Regional Vocational High School								
Project Name:		Northeast Metropolitan Regional Vocational High School				Reviewing Agency:		Consulting Engineering Services		
Project No.:		2022604.00 G				Reviewed By:		Chris Walczak		
Milestone:		60% CD				Review Date:		12/4/2022		
NO.	Drawing/ Spec Section	Detail/ Room Number	DISCIPLINE	Cx Review Comments	REVIEW COMMENT BY:		Designer Response	Follow Up Comments	Reviewer Response (Open/Closed)	Review Set
CES 6.01	A2-1-1	Detail 3	A	Recommend adding CW27 to "Curtain Wall Types" drawings.	CES		These curtain walls were labeled incorrectly, they should be CW25's. We have corrected the labeling.		Open	CD
CES 6.02	A2-1-6	Detail 3	A	This section of curtain wall, tagged CW23, does not appear to graphically match the CW23 detail shown on Drawing A6-3-4.	CES		Curtain wall was tagged incorrectly. It has now been fixed.		Open	CD
CES 6.03	A2-1-6	Detail 3	A	This section of curtain wall, tagged CW24, does not appear to graphically match the CW24 detail shown on Drawing A6-3-4.	CES		Curtain wall was tagged incorrectly. It has now been fixed.		Open	CD
CES 6.04	A5-3-1	Detail M	A	Roof vapor barrier not shown in detail. Recommend maintaining continuity of the vapor barrier at all equipment curb locations.	CES		Vapor barrier will be added to the detail.		Open	CD
CES 6.05	A5-3-1	Detail N, Q, O, K, H, G, F, E & D	A	Recommend adding a tag to identify the roof vapor barrier in this detail. (Typical)	CES		Will add appropriate notations.		Open	CD
CES 6.06	A5-3-1	Detail F & E	A	Should the sealant bead located beneath the stainless steel rain hood be tagged? (Typical)	CES		Will add appropriate notations.		Open	CD
CES 6.07	A6-3-2	Detail 1	A	Recommend moving the dimension label for graphical clarity.	CES		Will clean up dimensioning for better clarity.		Open	CD
CES 6.08	A6-3-2	Detail 1	A	Recommend reviewing conflicting labels. (Typical)	CES		Will review and resolve conflicting labels.		Open	CD
CES 6.09	A6-3-3	Detail 1	A	Recommend reviewing conflicting labels.	CES		Will review and resolve conflicting labels.		Open	CD
CES 6.10	A6-3-4	Detail 1	A	Recommend reviewing conflicting labels. (Typical)	CES		Will review and resolve conflicting labels.		Open	CD
CES 6.11	A6-3-4	Detail 1	A	Both curtain wall types are identified as CW25. Please clarify design intent.	CES		We have fixed the labeling conflict.		Open	CD
CES 6.12	A6-3-4	Detail 1	A	Both curtain wall types are identified as CW26. Please clarify design intent.	CES		We have fixed the labeling conflict.		Open	CD
CES 6.13	A6-3-6	Detail 1 & 2	A	Recommend reviewing conflicting labels. (Typical)	CES		Will review and resolve conflicting labels.		Open	CD
CES 6.14	A6-3-8	Detail 1	A	Recommend identifying component on graphical detail.	CES		Will indentify all components in detailing.		Open	CD